
Vendor Perspective on Spent Fuel Pool Criticality Analysis

NEI Used Fuel Management Conference
St. Petersburg, FL
May 8th, 2013

Topics of Discussion

- Westinghouse Methodology Topical Report
- NEI Guidance Document (NEI 12-16)
- Recent Issues in Criticality Applications
- Areas of Focus in the Future
- Summary

Westinghouse Topical Report – WCAP-17483

- Past practice has been to submit a site-specific methodology for each License Amendment Request (LAR).
- Westinghouse chose to pursue a generic methodology topical report to improve regulatory efficiency and reduce review time on LARs
- Spent Fuel Pool Criticality topical report submitted in December 2011.
- NRC provided review questions in March 2012.
- Westinghouse responded to NRC review questions in June 2012.
- Southern Nuclear provided letter of support in December 2012 to support an LAR submittal in 2014.

Westinghouse Topical Report – WCAP-17483

- Applicable to PWR UO₂ fuel and new and spent fuel storage rack designs.
- Methodology addresses all issues identified in ISG-DSS-2010-01
- Depletion calculations based on NRC approved PARAGON code (WCAP-16045-P-A).
- Depletion based on conservative operating parameters determined from core reload calculations.
- Criticality calculations based on SCALE/KENO. (Other codes possible to be used with proper validation)
- Criticality Code Validation included HTC experiments with expanded trend and statistical analysis.

NEI 12-16: Spent Fuel Criticality Guidance

- Applicable to BWR and PWR fuel/racks.
- Provides guidance to licensees/vendors on areas to be addressed in the criticality analysis – but not a prescriptive methodology.
- Addresses areas outside of the criticality analysis methodology:
 - Neutron Absorber Surveillance
 - Licensee Controls
- The NEI guidance document and Westinghouse methodology topical report can be used together in a complementary manner.

Recent Issues

- Conservatism of Neglecting Gadolinium
- Impact of Control Rod Insertion
- Multiple Misloaded Assemblies
- Justification of the Depletion Code Uncertainty
- Technical Specification Content
- Modeling of Boraflex Degradation
- Requests for Extraneous Information
- Administrative Controls

Future Industry Focus Areas

- Administrative Controls to prevent multiple misloaded assemblies and use of a risk informed approach.
- Creation of a COLR type document for the Spent Fuel Pool
- Further justification for reduction of the depletion uncertainty

Summary

- Continue to support utilities in performing spent fuel pool criticality analyses.
- Having an approved generic methodology will increase safety, regulatory certainty and decrease NRC review time needed for LAR reviews.

Vendor Perspective on Spent Fuel Pool Criticality Analysis

NEI Used Fuel Management Conference
St. Petersburg, FL
May 8th, 2013